

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Name and address of the applicant
Nom et adresse du demandeur

Name and address of the manufacturer
Nom et adresse du fabricant

Name and address of the factory
Nom et adresse de l'usine

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Trademark (if any)
Marque de fabrique (si elle existe)

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais
constructeur

Model / Type Ref.
Ref. De type

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,,
peuvent être indiqués sur la 2^{ème} page

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

As shown in the Test Report Ref. No. which forms
part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

Power Supply

XP POWER LLC
SUITE 150, 1241 E DYER RD
SANTA ANA CA 92705, USA

XP POWER LLC
SUITE 150, 1241 E DYER RD
SANTA ANA CA 92705, USA

XP POWER LLC
990 BENEZIA AVE
SUNNYVALE CA 94085
USA

Additional Information on page 2

Input: 100-240 Vac, 3.1 A, 50/60 Hz

Output: See Test Report Enclosure - Miscellaneous Ratings
Table for details.



SMT

CLC175USXX-M

Additionally evaluated to EN 60601-1:2006/CORR:2010;
National Differences specified in the CB Test Report.

Additional Information on page 2

IEC 60601-1(ed.3)

E146893-A35-CB-1 issued on 2012-01-11

This CB Test Certificate is issued by the National Certification Body

Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Yokohama Business Park, 134 Godo-cho, Hodogaya-ku, Kanagawa 240-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2012-01-11

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

US-18342-UL

Model Details:

CLC175USXX-M (where XX = 12-48; may also be followed by suffixes SF, A, C or TF)

Factories:

XP POWER (KUNSHAN) LTD
230 BIN JIANG NAN RD
ZHANGPU TOWN
KUNSHAN JIANGSU 215321
CHINA

Additional information (if necessary)

Information complémentaire (si nécessaire)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Yokohama Business Park, 134 Godo-cho, Hodogaya-ku, Kanagawa 240-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2012-01-11

Signature:

Jolanta M. Wroblewska



Test Report issued under
the responsibility of:



TEST REPORT
IEC 60601-1
Medical Electrical Equipment
Part 1: General requirements for basic safety and essential performance

Report Reference No: E146893-A35-CB-1

Date of issue: 2012-01-11

Total number of pages: 222

CB Testing Laboratory: UL San Jose

Address: 455 E. Trimble Rd., San Jose, CA, 95131-1230, USA

Applicant's name: XP POWER LLC
SUITE 150

Address: 1241 E DYER RD
SANTA ANA CA 92705
UNITED STATES

Test specification:

Standard: IEC 60601-1: 2005 + CORR. 1 (2006) + CORR. 2 (2007)

Test procedure: CB Scheme

Non-standard test method: N/A

Test Report Form No.: IEC60601_1G

Test Report Form originator: UL LLC


Master TRF: Dated 2010-11




Copyright © 2010 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this test Report is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

| | |
|------------------------------------|---|
| Test item description | Power Supply |
| Trade Mark |  |
| Manufacturer | XP POWER LLC SUITE 150 1241 E DYER RD SANTA ANA CA 92705 UNITED STATES |
| Model/Type reference | CLC175USXX-M (where XX = 12-48; may also be followed by suffixes SF, A, C or TF) |
| Ratings | Input: 100-240 Vac, 3.1 A, 50/60 Hz Output: See Enclosure - Miscellaneous Ratings Table for details. |

| | |
|---|---|
| Testing procedure and testing location: | |
| <input type="checkbox"/> CB Testing Laboratory | Testing location / address..... : |
| <input type="checkbox"/> Associated CB Test Laboratory | Testing location / address..... : |
| | Tested by (name + signature) : |
| | Approved by (name + signature) ... : |
| <input type="checkbox"/> Testing Procedure: TMP | Testing location / address..... : |
| | Tested by (name + signature) : |
| | Approved by (+ signature) : |
| | Testing location / address..... : |
| <input type="checkbox"/> Testing Procedure: WMT | Testing location / address..... : |
| | Tested by (name + signature) : |
| | Witnessed by (+ signature)..... : |
| | Approved by (+ signature) : |
| | Testing location / address..... : |
| <input checked="" type="checkbox"/> Testing Procedure: SMT | Testing location / address..... : |
| Tested by (name + signature) : | Rodney Reyes  |
| Approved by (+ signature) : | Tac Pham  |
| Supervised by (+ signature) : | Andrew Saunders  |
| Tested by (name + signature) : | XP Power LLC, 1241 E. Dyer Rd, Suite 150, Santa Ana, CA 92705, USA |
| <input type="checkbox"/> Testing Procedure: RMT | Testing location / address..... : |
| | Tested by (name + signature) : |
| | Approved by (+ signature) : |
| | Supervised by (+ signature) : |
| | Testing location / address..... : |

| | |
|---|------------------------------------|
| List of Attachments | |
| National Differences (9 pages) | |
| Enclosures (104 pages) | |
| Summary Of Testing | |
| Unless otherwise indicated, all tests were conducted at XP Power LLC, 1241 E. Dyer Rd, Suite 150, Santa Ana, CA 92705, USA. | |
| Tests performed (name of test and test clause) | Testing location / Comments |

Humidity Preconditioning Treatment (5.7)

Working Voltage Measurement (8.5.4)

Dielectric Voltage Withstand (8.8.3)

Abnormal Operation and Single Fault Conditions (13)

Transformer Overload and Short-Circuit Tests (15.5.1)

Leakage Current Test (8.7)


Summary of Compliance with National Differences:

List of countries addressed: AT, BE, CA, CH, CZ, DE, DK, FI, FR, GB, HU, IL, IT, NL, NO, PL, SE, SG, SI, SK, TR, UA, US

The product fulfills the requirements of: ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10), CAN/CSA-C22.2 No. 60601-1 (2008), IEC 60601-1: 2005, EN 60601-1: 2006 + CORR: 2010

Copy of Marking Plate

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.



| | |
|---|--|
| Test item particulars (see also Clause 6): | |
| Classification of installation and use | For building-in |
| Device type (component/sub-assembly/ equipment/ system) | Component |
| Intended use (Including type of patient, application location) | None |
| Mode of operation | Continuous |
| Supply connection | For building-in |
| Accessories and detachable parts included | None |
| Other options include | None |
| Testing: | |
| Date of receipt of test item(s) | 2011-08-05 |
| Dates tests performed | 2011-08-05 to 2011-12-15 |
| Possible test case verdicts: | |
| - test case does not apply to the test object | N / A |
| - test object does meet the requirement | P(Pass) |
| - test object was not evaluated for the requirement : | N / E |
| - test object does not meet the requirement | F(Fail) |
| Abbreviations used in the report: | |
| - normal condition | N.C. - single fault condition |
| - means of Operator protection | MOOP - means of Patient protection |
| General remarks: | |
| <p>"(see Attachment #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report.</p> <p>The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the testing laboratory. List of test equipment must be kept on file and available for review. Additional test data and/or information provided in the attachments to this report.</p> <p>Throughout this report a point is used as the decimal separator.</p> | |
| Manufacturer's Declaration per Sub Clause 6.25 of IEC60601-1: | |
| The application for obtaining a CB Test Certificate includes more than one factory and a declaration form the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided | Yes |
| When differences exist, they shall be identified in the General Product Information section. | |
| Name and address of Factory(ies): | XP POWER LLC 990 BENEZIA AVE SUNNYVALE CA 94085 UNITED STATES |

XP POWER (KUNSHAN) LTD
230 BIN JIANG NAN RD
ZHANGPU TOWN
KUNSHAN
JIANGSU 215321 CHINA

GENERAL PRODUCT INFORMATION:

Report Summary

All applicable tests according to the referenced standard(s) have been carried out.

Product Description

Products covered are open frame power supplies intended for building-in to be used with Medical Electrical Equipment. Units are intended for used with Class I or Class II end-products.

Marking label is representative of all models.

Model Differences

All models in the Model CLC175USXX-M Series are identical with exception to the Mains Transformer, T1, and minor secondary components that allow for different output voltage ratings. See below for 50°C output ratings:

Model CLC175US12-M: Output Rated: 12 Vdc, 13.9 A

Model CLC175US24-M: Output Rated: 24 Vdc, 6.9 A

Model CLC175US48-M: Output Rated: 48 Vdc, 3.5 A

All models provided with Fan Output (12Vdc, 0.5 A) and Standby Output (5.0 Vdc, 0.5A).

See Enclosure 7-01 for Output De-rating Table.

Suffix "SF" indicates single fuse provided in the line side of the primary.

Suffix "TF" indicates units provided with cover and top fan.

Suffix "C" indicates units provided with cover.

Suffix "A" indicates units provided with Transformer, T2.

Additional Information

This report has been previously evaluated by UL to IEC60601-1: 1988+A1: 1991 +A2: 1995, UL 60601-1, 1st Edition, 2006-04-26 (includes National Differences for USA) , EN 60601-1: 1990 + A1:1993 + A2:1995 , CAN/CSA-C22.2 No. 601.1-M90 (R2005) (includes National Differences for Canada) under CBTR Ref. No.E146893-A16-CB-1, CB Test Certificate Ref. No. US/15079/UL. Based on previously conducted testing and the previous review of product construction only limited tests were deemed necessary.

Technical Considerations

- The product was investigated to the following additional standards: ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) (includes Deviations for United States), CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) (includes National Differences for Canada), EN 60601-1: 2006 + CORR: 2010

(Medical electrical equipment Part 1: General requirements for basic safety and essential performance)

- The product was not investigated to the following standards or clauses: Biocompatibility (ISO 10993-1), Clause 14, Programmable Electronic Systems, Electromagnetic Compatibility (IEC 60601-1-2)
- The degree of protection against harmful ingress of water is: Ordinary
- The mode of operation is: Continuous
- The product is suitable for use in the presence of a flammable anesthetics mixture with air or oxygen or with nitrous oxide: No
- Unit also complied with spacing requirements of UL60601-1 (1st), CSA C22.2 No. 60601-1 (2nd), and IEC 60601-1 (2nd) for Basic for 250 Vac from Primary to Ground, Double/Reinforced for 250 Vac from Primary to Secondary. --
- The power supply was evaluated for use in 50°C ambient at Full Rated Output and 50% of the Rated Output in 70°C ambient. (See De-rating Curve, Enclosure 7-01 for details) --

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

- The component shall be considered for compliance with the Marking (clause 7) and Separation (clause 8) requirements as part of the end use application evaluation. --
- Repeat of leakage current testing and consideration of non-frequency weighted leakage to be considered as part of the end product. --
- This power supply was evaluated with Two MOPP between Primary and Secondary; One MOPP between primary and Earth; only operational protection between secondary and Earthed trace or chassis for both class I and class II application. --
- This power supply has been evaluated as a continuous operation, ordinary equipment and has not been evaluated for use in the presence of a flammable anesthetic mixture with air, oxygen, or nitrous oxide. The output circuits have not been evaluated for direct patient connection (Type B, BF or CF). -
-
- The end product shall ensure that the requirements related to accompanying documents, clause 7.9, are met. --
- The available voltage for the secondary outputs does not exceed 25 Vac or 60 Vdc, under normal and single fault conditions. --

- The following secondary output circuits are at hazardous energy levels: Main Power Output --
- The output connectors are not acceptable for field connections; they are only intended for connection to mating connectors of the end-use equipment. --
- The Dielectric Strength Test conducted on this power supply was based upon a maximum working voltage of: Primary-Earthed Dead Metal (Class I units): 347 Vpk, 250 Vrms; Primary-SEC: 525 Vpk, 250 Vrms. --
- For Class I application: Protective bonding testing shall be considered in the end product application. --
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): L1 and T1 (Class F, 155°C) --
- Printed Wiring Board rated 130°C. --
- Cleaning test shall be considered as part of end product evaluation. --
- The need for Marking Durability and Marking Legibility Testing shall be considered as part of the end product installation. --
- Fire/ Mechanical/ Electrical Enclosure to be provided as part of the end product. --
- When installed in a Class I end product, the power supply shall be mounted in a manner that provides, at a minimum, 2.5 mm Clearance/4 mm Creepage between the primary sides of power supply and protectively earthed accessible conductive parts. In addition, when installed in a Class I end product, the protective bonding terminal of the power supply shall be reliably connected to the main protective earthing terminal of the end product. --
- When installed in a Class II end product, the power supply shall be mounted, on insulating posts, in a manner that provides, at a min. 5 mm Clearance/8 mm Creepage between the power supply and any accessible conductive parts. --
- Units provided with either a Cover or Chassis should be used only in a Class I application with earthing symbol applied. The cover and chassis shall be reliably earthed in the end-use application. --
- Units may be provided with one fuse in the Line side for models with SF suffix or one fuse in both the Line and Neutral sides. The need for additional fusing shall be determined as part of the end-product evaluation. --
- Temperature test conducted with approx 12CFM top fan model forced air cooling, temperature on on Convection cooling condition or other external forced air cooling shall be determined in the end

product evaluation. --

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Switching Power Supply

Name and address of the applicant
Nom et adresse du demandeur

XP POWER LLC
SUITE 150, 1241 E DYER RD
SANTA ANA CA 92705, USA

Name and address of the manufacturer
Nom et adresse du fabricant

XP POWER LLC
SUITE 150, 1241 E DYER RD
SANTA ANA CA 92705, USA

Name and address of the factory
Nom et adresse de l'usine

XP POWER LLC
990 BENEZIA AVE
SUNNYVALE CA 94085
USA

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Additional Information on page 2
Input: 100-240 Vac, 50/60Hz, 3.1 A
Output: See Test Report for details.

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Trademark (if any)
Marque de fabrique (si elle existe)



WMT

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais
constructeur

CLC175USXX, CLC175US12-XA0505A
See Page 2

Model / Type Ref.
Ref. De type

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,,
peuvent être indiqués sur la 2^{ème} page

Additionally evaluated to EN 60950-1:2006/ A11:2009/ A1:2010/
A12:2011; National Differences specified in the CB Test Report.

Additional Information on page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60950-1(ed.2), IEC 60950-1(ed.2);am1

As shown in the Test Report Ref. No. which forms
part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

E139109-A75-CB-2 issued on 2012-10-03

This CB Test Certificate is issued by the National Certification Body

Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2012-10-03

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

US-19875-UL

Model Details:

CLC175USXX, (where the "XX" can be any number between 12 to 48 indicating main output voltage), may be provided with additional "-A" suffix.

Factories:

XP POWER (KUNSHAN) LTD
230 BIN JIANG NAN RD
ZHANGPU TOWN
KUNSHAN
JIANGSU 215321
CHINA

Additional information (if necessary)

Information complémentaire (si nécessaire)



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2012-10-03

Signature:

Jolanta M. Wroblewska



Test Report issued under
the responsibility of:



TEST REPORT
IEC 60950-1
Information technology equipment - Safety -
Part 1: General requirements

Report Reference No: E139109-A75-CB-2

Date of issue: 2012-10-03

Total number of pages: 66

CB Testing Laboratory: UL San Jose

Address: 455 E. Trimble Rd., San Jose, CA, 95131-1230, USA

Applicant's name: XP POWER LLC
SUITE 150

Address: 1241 E DYER RD
SANTA ANA CA 92705

Test specification:

Standard: IEC 60950-1:2005 (2nd Edition); Am 1:2009

Test procedure: CB Scheme

Non-standard test method: N/A

Test Report Form No.: IEC60950_1B

Test Report Form originator: SGS Fimko Ltd


Master TRF: 2010-04




Copyright © 2010 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this test Report is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

| | |
|------------------------------------|--|
| Test item description | Switching Power Supply |
| Trade Mark |  |
| Manufacturer | XP POWER LLC SUITE 150 1241 E DYER RD SANTA ANA CA 92705 UNITED STATES |
| Model/Type reference | CLC175USXX, (where the "XX" can be any number between 12 to 48 indicating main output voltage), may be provided with additional "-A" suffix. CLC175US12-XA0505A |
| Ratings | Input: 100-240 Vac, 50/60Hz, 3.1 A Output: See Model Differences for details. |

| | |
|--|---|
| Testing procedure and testing location: | |
| <input type="checkbox"/> | CB Testing Laboratory Testing location / address..... : |
| <input type="checkbox"/> | Associated CB Test Laboratory Testing location / address..... : Tested by (name + signature) : _____ Approved by (name + signature) ... : _____ |
| <input type="checkbox"/> | Testing Procedure: TMP Tested by (name + signature) : _____ Approved by (+ signature) : _____ Testing location / address..... : _____ |
| <input checked="" type="checkbox"/> | Testing Procedure: WMT Tested by (name + signature) : Rodney Reyes  Witnessed by (+ signature) : Sal Oseguera  Approved by (+ signature) : Linus Park  Testing location / address..... : XP Power LLC, Suite 50, 1241 E. Dyer Rd., Santa Ana, CA 92705 USA |
| <input type="checkbox"/> | Testing Procedure: SMT Tested by (name + signature) : _____ Approved by (+ signature) : _____ Supervised by (+ signature) : _____ Testing location / address..... : _____ |
| <input type="checkbox"/> | Testing Procedure: RMT Tested by (name + signature) : _____ Approved by (+ signature) : _____ Supervised by (+ signature) : _____ Testing location / address..... : _____ |

| | |
|--|------------------------------------|
| List of Attachments | |
| National Differences (37 pages) | |
| Enclosures (72 pages) | |
| Summary Of Testing | |
| Unless otherwise indicated, all tests were conducted at XP Power LLC, Suite 50, 1241 E. Dyer Rd., Santa Ana, CA 92705 USA. | |
| Tests performed (name of test and test clause) | Testing location / Comments |

Power Supply Reference Page

Guide Information Page - Maximum Output Voltage, Current, and Volt Ampere Measurement (1.2.2.1)

Input: Single-Phase (1.6.2)

Capacitance Discharge (2.1.1.7)

SELV Reliability Test Including Hazardous Voltage Measurements (2.2.2, 2.2.3, 2.2.4, Part 22 6.1)

Humidity (2.9.1, 2.9.2, 5.2.2)

Determination of Working Voltage; Working Voltage Measurement (2.10.2)

Thin Sheet Material (2.10.5.9, 2.10.5.10, 2.10.5.6)

Transformer and Wire /Insulation Electric Strength (2.10.5.13)

Heating (4.5.1, 1.4.12, 1.4.13)

Touch Current (Single-Phase; TN/TT System) (5.1, Annex D)

Electric Strength (5.2.2)

Transformer Abnormal Operation (5.3.3, 5.3.7b, Annex C.1)

Power Supply Output Short-Circuit/Overload (5.3.7)

Summary of Compliance with National Differences:

Countries outside the CB Scheme membership may also accept this report.

List of countries addressed: AT, BE, BG, CA, CH, CN, CZ, DE, DK, ES, EU, FI, FR, GB, GR, HU, IE, IL, IT, JP, KR, NL, PL, PT, RO, SE, SI, SK, UA, US

The product fulfills the requirements of: CSA C22.2 No. 60950-1-07 + A1:2011, EN 60950-1:2006 + A1:2010 + A11:2009 + A12:2011, UL 60950-1 2nd Ed. Revised 2011-12-19, IEC 60950-1:2005 + A1:2009

Copy of Marking Plate - Refer to Enclosure titled Marking Plate for copy.

| | |
|---|--|
| Test item particulars : | |
| Equipment mobility | for building-in |
| Connection to the mains | for building-in |
| Operating condition | continuous |
| Access location | for building-in |
| Over voltage category (OVC) | OVC II |
| Mains supply tolerance (%) or absolute mains supply values | +10%, -10% |
| Tested for IT power systems | No |
| IT testing, phase-phase voltage (V) | N/A |
| Class of equipment | Class I or Class II (Determined by end product) |
| Considered current rating of protective device as part of the building installation (A) | 20 A |
| Pollution degree (PD) | PD 2 |
| IP protection class | IP X0 |
| Altitude of operation (m) | 5000 |
| Altitude of test laboratory (m) | 200 |
| Mass of equipment (kg) | 0.175 |
| Possible test case verdicts: | |
| - test case does not apply to the test object | N / A |
| - test object does meet the requirement | P(Pass) |
| - test object does not meet the requirement | F(Fail) |
| Testing: | |
| Date(s) of receipt of test item | 2012-09-07, 2011-05-02 |
| Date(s) of Performance of tests | 2012-09-12 to 2012-09-25, 2011-05-05 to 2011-05-19 |
| General remarks: | |
| The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the testing laboratory. "(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report. Throughout this report a point is used as the decimal separator. | |
| Manufacturer's Declaration per Sub Clause 6.25 of IEC60950: | |
| The application for obtaining a CB Test Certificate includes more than one factory and a declaration form the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided | Yes |
| When differences exist, they shall be identified in the General Product Information section. | |
| Name and address of Factory(ies): | XP POWER LLC |

990 BENEZIA AVE
SUNNYVALE CA 94085
UNITED STATES

XP POWER (KUNSHAN) LTD
230 BIN JIANG NAN RD
ZHANGPU TOWN
KUNSHAN
JIANGSU 215321 CHINA

GENERAL PRODUCT INFORMATION:

Report Summary

All applicable tests according to the referenced standard(s) have been carried out.

Product Description

Products are switching power supplies for building-in to Information Technology Equipment. It is an open frame power supply intended for building-in Class I or Class II end-products.

Model Differences

The power supplies in the series are differentiated by the output voltage and current ratings, number of turns of secondary winding in the Isolation Transformers (T1) and minor differences in the secondary circuit components and PWB layout.

Model CLC175US12-XA0505A is identical to CLC175US12

Models provided with suffix "-A" provided with additional standby transformer T2.

Output Ratings:

CLC175US12: 12Vdc, 13.9A

CLC175US24: 24Vdc, 6.9A

CLC175US28: 28Vdc, 6.25A

CLC175US48: 48Vdc, 3.5A

Additional Information

This CB Report is a reissue of CBTR Ref. No. E139109-A75-CB-1, CB Test Certificate Ref. No. US-17149-UL. Based on previously conducted testing and review of product construction, only limited testing was deemed necessary.

Required values for clearance are adjusted for 5000 m (1.48 correction factor as per IEC 60664-1, Table A2).

The need for the additional testing and evaluation shall be determined in the end product investigation.

The power supply covered by this report employs Double/Reinforced Insulation between Primary and Secondary circuits.

Technical Considerations

- The product was submitted and evaluated for use at the maximum ambient temperature (T_{ma})

permitted by the manufacturer's specification of: 50°C (See De-rating Curve, Enclosure 7-06, for details) ,

- The means of connection to the mains supply is: for building-in, to be determined in end-product., ,
- The product is intended for use on the following power systems: TN
- The equipment disconnect device is considered to be: provided as part of the end product.,
- The product was investigated to the following additional standards: EN 60950-1:2006 + A11:2009 + A12:2010 + A12:2011 (which includes all European national differences, including those specified in this test report).

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

- The following Production-Line tests are conducted for this product: Earthing Continuity, Electric Strength
- The end-product Electric Strength Test is to be based upon a maximum working voltage of: Primary-Earthed: 362 Vrms, 246Vpk, Primary-SELV: 475 Vrms, 243 Vpk,
- The following secondary output circuits are SELV: All outputs
- The power supply terminals and/or connectors are: Not investigated for field wiring
- The maximum investigated branch circuit rating is: 20 A
- The investigated Pollution Degree is: 2
- Proper bonding to the end-product main protective earthing termination is: Required
- An investigation of the protective bonding terminals has: Not been conducted
- The following input terminals/connectors must be connected to the end-product supply neutral: J1-N
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): L1, L2, L3 and T1 (Class F, 155°C),
- The following end-product enclosures are required: Mechanical, Fire
- When mounted inside the chassis, adequate creepage/ clearance shall be provided between live

parts, including primary and secondary heatsinks, and accessible metal parts. --

- Suitable disconnect device is to be provided in the end system. --
- Temperature, Leakage and Dielectric Strength testing shall be considered in the end system. --
- The need for protective bonding test to be determined as part of the end product evaluation. --
- Required values for clearance are adjusted for 5000 m (1.48 correction factor as per IEC 60664-1, Table A2) --
- The maximum continuous power rating of 175W relied on forced air cooling from a 10 cfm fan located 2.5 cm away blowing from input to output. The need for additional cooling to be considered as part of the end product. --

Abbreviations used in the report:

| | | | |
|--|------|----------------------------------|-------|
| - normal condition | N.C. | - single fault condition | S.F.C |
| - operational insulation | OP | - basic insulation | BI |
| - basic insulation between parts of opposite polarity: | BOP | - supplementary insulation | SI |
| - double insulation | DI | - reinforced insulation | RI |

Indicate used abbreviations (if any)