

## Feed-through terminal block - UHK 4-LOER/FS(10-2,8-0,8) - 2017208

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (<http://phoenixcontact.com/download>)



Feed-through terminal block, Connection method: Slip-on connection, Cross section: 0.2 mm<sup>2</sup> - 1.5 mm<sup>2</sup>, AWG: 24 - 16, Width: 6.2 mm, Color: gray, Mounting type: NS 35/7,5, NS 35/15, NS 32

The figure shows a similar product

### Key commercial data

Packing unit	1 pc
GTIN	 4 017918 052669
Weight per Piece (excluding packing)	9.4 GRM
Custom tariff number	85369010
Country of origin	Poland

### Technical data

#### General

Number of levels	1
Number of connections	11
Color	gray
Inflammability class according to UL 94	V2
Rated surge voltage	6 kV
Pollution degree	3
Surge voltage category	III
Insulating material group	I
Nominal current I <sub>N</sub> (lower level)	40 A (The nominal current must not be exceeded by the total current of all connected conductors.)
Nominal voltage U <sub>N</sub>	400 V (The rated insulation voltage applies for fully insulated slip-on sleeves.)
Open side panel	ja

#### Dimensions

Width	6.2 mm
-------	--------

## Feed-through terminal block - UHK 4-LOER/FS(10-2,8-0,8) - 2017208

### Technical data

#### Dimensions

Length	63 mm
Height NS 35/7,5	51.5 mm
Height NS 35/15	59 mm
Height NS 32	56.5 mm

#### Connection data

Connection method	Slip-on connection
Conductor cross section solid min.	0.2 mm <sup>2</sup>
Conductor cross section solid max.	1.5 mm <sup>2</sup>
Conductor cross section stranded min.	0.2 mm <sup>2</sup>
Conductor cross section stranded max.	1.5 mm <sup>2</sup>
Conductor cross section AWG/kcmil min.	24
Conductor cross section AWG/kcmil max	16
Connection method	Solder connection

### Classifications

#### eCl@ss

eCl@ss 4.0	27141120
eCl@ss 4.1	27141120
eCl@ss 5.0	27141120
eCl@ss 5.1	27141120
eCl@ss 6.0	27141120
eCl@ss 7.0	27141120
eCl@ss 8.0	27141120

#### ETIM

ETIM 2.0	EC000897
ETIM 3.0	EC000897
ETIM 4.0	EC000897
ETIM 5.0	EC000897

#### UNSPSC

UNSPSC 6.01	30211811
UNSPSC 7.0901	39121410
UNSPSC 11	39121410
UNSPSC 12.01	39121410
UNSPSC 13.2	39121410

## Feed-through terminal block - UHK 4-LOER/FS(10-2,8-0,8) - 2017208

### Approvals

Approvals

---

Approvals

LR / PRS

---

Ex Approvals

---

Approvals submitted

---

### Approval details

LR
----

PRS
-----

---