

Product Change Notification

PCN-AI-7532-2021

Business Unit	Product Line Code	Type of Change	Action	Date of Issue
AI - Automation Infrastructure	DNA	Product Change Notification	Notify Distributors and Field	12/21/2021

The following Phoenix Contact products have been modified. Existing specifications will be met or exceeded. Please review and acknowledge this document and inform your personnel as needed.

Description for Product Change Notification

Purpose/objective of the change

Change to the hardware revision of the items to optimize the field of application.

Detailed description of the change

Due to the hardware change, the listed items can no longer be operated via an AC supply voltage, and are therefore only compatible with old item versions to a limited extent. The modified technical values are listed in the attachment. In addition, non-coded plugs will be installed, the packing slip will be changed over to a new documentation concept, and a smaller folding carton will be used.

Identifying characteristics

In addition to the year of manufacture, the calendar week will also be displayed below the CE mark. The various pictograms and TÜV approvals will be displayed in the lower area on the left half of the housing; the plug will no longer be coded.

Stock Status

Can existing stock still be used?	Yes
Is mixture of stock acceptable?	No















Transaction Dates

Date modification goes into effect from Germany:	4/22/2022
Expected first shipment (from Phoenix Contact) of the modified products(s):	4/22/2022



Phoenix Contact Inc.
P.O. BOX 4100
Harrisburg, PA 17111-0100
Phone: 717-944-1300

Product Change Notification

Previous Product	New Product
 <p>PHOENIX CONTACT PHOENIX CONTACT GmbH & Co.KG Flachmarkstrasse 8 32825 Blomberg, Germany</p> <p>PSR-SCP-24VDC/ESAM/BK1V12 Ord.-No: 28 83 91 2</p> <p>Phoenix Safety Relays</p> <p>INPUT  24V AC/DC -15 +10% </p> <p>OUTPUT  230V AC : 6A 230V AC15: 3A (4A-360 cycles/h) 24V DC13: 2,5A (4A-360 cycles/h)</p> <p>Read installation instructions before connecting to mains www.phoenixcontact.com</p>	 <p>PHOENIX CONTACT PHOENIX CONTACT GmbH & Co.KG Flachmarkstrasse 8 32825 Blomberg, Germany</p> <p>PSR-SCP-24VDC/ESAM/BK1V12 Ord.-No: 28 83 91 8</p> <p>PSR Safety Relays</p> <p>INPUT  24V DC -15 +10% </p> <p>OUTPUT  230V AC : 6A 230V AC15: 3A 24V DC13: 2,5A</p> <p>Documentation</p> <p></p>
 <p>APPROVALS</p> <p> 30-12 AWG 5-7 lbs-ins. Input: 24Vac/dc IND. CONT. EQ. 32FB</p> <p>Output: 240V ac/24V dc, 6A B300 Pilot duty R300 Pilot duty</p> <p></p> <p>HW/FW: 16/---</p> <p>XXXXXXXXXX (Seriennr.)</p> <p>13 23 33 43 53 63 73 83 91 14 24 34 44 54 64 74 84 92</p>	 <p>APPROVALS</p> <p> 30-12 AWG 5-7 lbs-ins. Input: 24V dc IND. CONT. EQ. 32FB</p> <p>Output: 240V ac/24V dc, 6A B300 Pilot duty R300 Pilot duty</p> <p>XXXXXXXXXX (Seriennr.)</p> <p>13 23 33 43 53 63 73 83 91 14 24 34 44 54 64 74 84 92</p>

Phoenix Contact Inc.
P.O. BOX 4100
Harrisburg, PA 17111-0100
Phone: 717-944-1300


Product Change Notification



Should you have any issues with the timeline or content of this product change, please contact Phoenix Contact using the information below. Customers should acknowledge receipt of the PCN within 30 days of delivery of the PCN; provided, however, that the failure to acknowledge receipt does not affect the product change or the effective date thereof.

Contact Info:
Zachary Stank
zstank@phoenixcontact.com

Thank you,



Zachary Stank
Product Marketing Manager



Phoenix Contact Inc.
P.O. BOX 4100
Harrisburg, PA 17111-0100
Phone: 717-944-1300

Product Change Notification

Part #	Type Description
2900525	PSR-SCP- 24UC/ESAM4/2X1/1X2
2900526	PSR-SPP- 24UC/ESAM4/2X1/1X2
2900509	PSR-SCP- 24UC/ESAM4/3X1/1X2/B
2900510	PSR-SPP- 24UC/ESAM4/3X1/1X2/B