

## PRODUCT CHANGE NOTIFICATION

#PCN-TT-0SW0-14

Business Unit	Product Line Code	Type of Change	Action	Date of issue
TT	CL2	Electrical	Notify Distributors and Field	5/28/2014

*The following Phoenix Contact products have been modified. Existing specifications will be met or exceeded. Please review and acknowledge this document and inform your personnel as needed.*

### Description of Change:

Technical data has been updated based on IEC 61643-21 tests:

- 1) The IEC class has been expanded from C2 to C1, C2, C3, D1
- 2) U<sub>c</sub> of PT2x1VA-230AC has increased from 250 V AC to 275V AC
- 3) The DC values for PT2x1VA-120AC and -230AC have been removed.

### Warranty Information:

N/A

### Stock Status

Can existing stock still be used? Y



Is mixture of stock acceptable? Y

### Transaction Dates:

Date modification goes into effect from Germany: 3/7/2014

Expected first shipment (from Phoenix Contact) of the modified product(s): April 2014

## PRODUCT CHANGE NOTIFICATION

Previous Product	New Product
 <p>PHOENIX CONTACT PLUGTRAB PT 2x1VA 230AC-ST U<sub>C</sub>: 250 V AC I<sub>N</sub>: 26 A E-029 CE 28 39 19 8</p>	 <p>PHOENIX CONTACT PLUGTRAB PT 2x1VA 230AC-ST U<sub>C</sub>: 275 V AC I<sub>N</sub>: 26 A E-029 CE 28 39 19 8</p>

*Should you have any issues with the timeline or content of this change, please contact Phoenix Contact using the contact information below. Customers should acknowledge receipt of the PCN within 30 days of delivery of the PCN; provided, however that the failure to acknowledge receipt does not affect the product change or the effective date thereof.*

**Contact Info:**

Matt Hemphill  
mhemphill@phoenixcon.com  
(717) 944-1300 x3367

Thank you,



---

Surge and Overcurrent Protection, Product Marketing Manager

## PRODUCT CHANGE NOTIFICATION

Part#	Type Description
2839172	PT 2X1VA- 60AC-ST
2839185	PT 2X1VA-120AC-ST
2839198	PT 2X1VA-230AC-ST