SIEMENS

Data sheet

3RU2116-4AB1



Overload relay 11...16 A Thermal For motor protection Size S00, Class 10 Stand-alone installation Main circuit: Screw Auxiliary circuit: Screw Manual-Automatic-Reset

product brand name	SIRIUS		
product designation	thermal overload relay		
product type designation	3RU2		
General technical data			
size of overload relay	S00		
size of contactor can be combined company-specific	S00		
power loss [W] for rated value of the current at AC in hot operating state	8.1 W		
• per pole	2.7 W		
insulation voltage with degree of pollution 3 at AC rated value	690 V		
surge voltage resistance rated value	6 kV		
maximum permissible voltage for safe isolation in networks with grounded star point			
 between auxiliary and auxiliary circuit 	440 V		
 between auxiliary and auxiliary circuit 	440 V		
 between main and auxiliary circuit 	440 V		
 between main and auxiliary circuit 	440 V		
shock resistance according to IEC 60068-2-27	8g / 11 ms		
type of protection according to ATEX directive 2014/34/EU	Ex II (2) GD		
certificate of suitability according to ATEX directive 2014/34/EU	DMT 98 ATEX G 001		
reference code according to IEC 81346-2	F		
Substance Prohibitance (Date)	10/01/2009		
Ambient conditions			
installation altitude at height above sea level maximum	2 000 m		
ambient temperature			
 during operation 	-40 +70 °C		
 during storage 	-55 +80 °C		
during transport	-55 +80 °C		
temperature compensation	-40 +60 °C		
relative humidity during operation	10 95 %		
Main circuit			
number of poles for main current circuit	3		
adjustable current response value current of the current-dependent overload release	11 16 A		
operating voltage			
rated value	690 V		
 at AC-3e rated value maximum 	690 V		
operating frequency rated value	50 60 Hz		

operational current rated value	16 A
operational current at AC-3e at 400 V rated value	16 A
operating power	
• at AC-3	
- at 400 V rated value	7.5 kW
— at 500 V rated value	7.5 kW
— at 690 V rated value	11 kW
• at AC-3e	
- at 400 V rated value	7.5 kW
— at 500 V rated value	7.5 kW
— at 690 V rated value	11 kW
Auxiliary circuit	
design of the auxiliary switch	integrated
number of NC contacts for auxiliary contacts	1
note	for contactor disconnection
number of NO contacts for auxiliary contacts	1
note	for message "Tripped"
number of CO contacts for auxiliary contacts	0
operational current of auxiliary contacts at AC-15	
• at 24 V	3 A
• at 24 V	3 A
• at 120 V	3 A
• at 125 V	3 A
• at 230 V	2 A
• at 400 V	1 A
operational current of auxiliary contacts at DC-13	
• at 24 V	2 A
• at 60 V	0.3 A
• at 110 V	0.22 A
• at 125 V	0.22 A
• at 220 V	0.11 A
contact rating of auxiliary contacts according to UL	B600 / R300
Protective and monitoring functions	
trip class	CLASS 10
design of the overload release	thermal
UL/CSA ratings	
full-load current (FLA) for 3-phase AC motor	
at 480 V rated value	16 A
at 400 V rated value	16 A
Short-circuit protection	
design of the fuse link	
6	fue $\alpha C \in A$ quick: 10 A
 for short-circuit protection of the auxiliary switch required 	fuse gG: 6 A, quick: 10 A
Installation/ mounting/ dimensions	
mounting position	any
fastening method	stand-alone installation
height	89 mm
width	45 mm
depth	80 mm
Connections/ Terminals	
product component removable terminal for auxiliary	No
and control circuit	
type of electrical connection	
• for main current circuit	screw-type terminals
 for auxiliary and control circuit 	screw-type terminals
arrangement of electrical connectors for main current circuit	Top and bottom
type of connectable conductor cross-sections	
for main contacts	
— solid or stranded	2x (0,5 1,5 mm²), 2x (0,75 2,5 mm²), 2x 4 mm²

-	nded with core end process	sing		.5 1.5 mm²), 2x (0.7			
	for main contacts		2x (2	0 16), 2x (18 14),	2x 12		
	conductor cross-section	IS					
 for auxiliary cor 							
 — solid or stranded — finely stranded with core and processing 			2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)				
— finely stranded with core end processing		2x (0.5 1.5 mm ²), 2x (0.75 2.5 mm ²)					
	for auxiliary contacts		2x (2	0 16), 2x (18 14)			
tightening torque							
 for main contact 	cts with screw-type terminal	ls		. 1.2 N·m			
	ntacts with screw-type term	ninals		. 1.2 N·m			
design of screwdriv	er shaft			eter 5 6 mm			
size of the screwdri	•		Pozic	lriv PZ 2			
•	I of the connection screw	/					
 for main contact 			M3				
-	and control contacts		M3				
Safety related data							
failure rate [FIT] with 31920	low demand rate according	g to SN	50 FI	Т			
MTTF with high dem	nand rate		2 280) у			
	t interval or service life acc	cording to	20 y				
protection class IP of 60529	on the front according to	IEC	IP20				
	the front according to IE	C 60529	finge	r-safe, for vertical cont	act from the front		
Display	_						
display version for sw	vitching status		Slide	switch			
	ls						
Certificates/ approval						For use in hazard-	
		_	-			For use in hazard- ous locations	
Certificates/ approval							
Certificates/ approval		Confirmatio	<u>n</u>		FDF		
Certificates/ approval		Confirmatio	<u>n</u>	መ	FAL		
Certificates/ approval		Confirmatio	<u>n</u>	(h)	EAC		
Certificates/ approval		Confirmatio	<u>n</u>	U L	EAC		
Certificates/ approval		Confirmatio	n	U L	EAC		
Certificates/ approval General Product Ap			n	U L	EAC	ous locations	
Certificates/ approval			n	UL UL Test Certificates	EAC		
Certificates/ approval General Product Ap			n		EAC Special Test Cartific	ous locations	
Certificates/ approval General Product Ap			n	Type Test Certific-	EAC Special Test Certific- ate	ous locations	
Certificates/ approval General Product Ap			n		EAC Special Test Certific- ate	ous locations	
Certificates/ approval General Product Ap			n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Certifi	oproval CCC Declaration of Conform		n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Certifi	oproval CCC Declaration of Conform		n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Cer	oproval CCC Declaration of Conform		n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Certifi	oproval CCC Declaration of Conform		n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Cer	oproval CCC Declaration of Conform		n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Cer	oproval CCC Declaration of Conform		n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Cer	oproval CCC Declaration of Conform CCC EG-Konf.	nity Hoyds Register	n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Cer	oproval CCC Declaration of Conform		n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Certifi	oproval CCC Declaration of Conform CCC EG-Konf.	nity Hoyds Register		Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Certifi	Declaration of Conform	nity Hoyds Register	n	Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Certifi	oproval CCC Declaration of Conform CCC EG-Konf.	nity Hoyds Register		Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Certifi	oproval CCC Declaration of Conform CCC EG-Konf. Railway	nity Hoyds Register		Type Test Certific-		ous locations	
Certificates/ approval General Product Ap Certificates/ approval General Product Ap Certificates/ approval Certificates/ approval Certifi	Declaration of Conform	nity Hoyds Register		Type Test Certific-		ous locations	

Further information

Information- and Downloadcenter (Catalogs, Brochures,...) https://www.siemens.com/ic10 Industry Mall (Online ordering system) https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RU2116-4AB1 Cax online generator http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RU2116-4AB1 Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3RU2116-4AB1


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)


http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RU2116-4AB1&lang=en


Characteristic: Tripping characteristics, I²t, Let-through current


https://support.industry.siemens.com/cs/ww/en/ps/3RU2116-4AB1/char

Further characteristics (e.g. electrical endurance, switching frequency) http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RU2116-4AB1&objecttype=14&gridview=view1









last modified:

3/8/2022 🖸